

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0447:135 Page 1 of 1

CATEGORY: Annunciators

LISTEE: ESL/Sentrol, 12345 SW Levetron Drive, Tualatin, OR 97062
Contact: Gene Hukkanen (503) 691-7369

DESIGN: Models 606U1A, 606U2A, 606U3A, 606U4A, 706U1, 706U1A, 706U2, 706U2A, 706U3A and 706U4A smoke detector remote annunciators with test switch feature. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as remote annunciators for use with Models 611U and 611-UT (CSFM Listing No. 7272-0447:114) photoelectric smoke detectors and Model 612U (CSFM Listing No. 7271-0447:116) ionization smoke detector.

07-18-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager